



GUJARAT INDUSTRIES POWER COMPANY LIMITED

(SURAT LIGNITE POWER PLANT)

AT & PO. Nani Naroli, Taluka Mangrol, Dist. Surat - 394 112

Phone : EPABX (02629) 261063 to 261066 Fax : (02629) 261080 E-mail : genslpp@gipcl.com

Appendix VII

FIRE SAFETY CERTIFICATE No.

Dated: 10/03/2025

Certified that Bharatiya Vidya Bhavan's GIPCL Academy at Nani Naroli, Ta.: Mangrol, Dist. Surat, Gujarat – 394 112 comprised of ground floor and first floor owned / occupied by Bharatiya Vidya Bhavan's GIPCL Academy (Gujarat Industries Power Company Limited (GIPCL-SLPP)) have complied with the fire prevention and fire safety requirements in accordance with rule of State/UT Fire Service Rules, and verified by the competent Fire officials of Gujarat Industries Power Company Limited (Surat Lignite Power Plant) during inspection on 06/03/2025; and that the Building / premises is fit for occupancy class I to XII along with KG Classes. This certificate is valid with effect from 10/03/2025 for a period of one year in accordance with rule and subject to compliance of the conditions.

Issued on 10/03/2025 at Nani Naroli by

Signature with Seal:

Name:

Shri H. P. Rao

Designation:

GM (HR & A, S & F)

GIPCL, Nani Naroli

To

The Principal

Bharatiya Vidya Bhavan's GIPCL Academy

At & Po.: Nani Naroli, Ta.: Mangrol

Dist.: Surat – 394 112

ENDORSEMENT

The No Objection Certificate issued by Fire Service stand cancelled and annulled due to

.....

..... (reasons to be recorded).

(Name and designation of the authorized signatory)

Registered Office & Vadodara Plant :
P.O. RANOLI, Dist. Vadodara 391 350 Gujarat - INDIA



Phone : EPABX (0265) 2230182 / 2230028 / 2232768
Fax : 2230029 **E-mail :** genbaroda@gipcl.com

Website: www.gipcl.com
CIN No.: L99999GJ1985PLC007868

NANI NAROLI GROUP GRAM PANCHAYAT
TA.: MANGROL, DIST.: SURAT – 394 110

No.: 54/2024

Date: 10/03/2025

TO WHOMSOEVER IT MAY CONCERN

NO OBJECTION CERTIFICATE OF FIRE SAFETY

This is to certify that the management of “BHARATIYA VIDYA BHAVAN’S GIPCL ACADEMY”, At & Po.: Nani Naroli, Ta.: Mangrol, Dist.: Surat is having K G Classes, Primary, Secondary and Sr. Secondary School is running in Ground Floor + 1st Floor.

In this school following firefighting equipment's are installed, so this “No Objection Certificate” issued, against following equipments:

1. There is a Gujarat Industries Power Company Ltd. is situated at the opposite of school and they have **02 (Two) Fire Engines with sufficient and experience staff.**
2. 9 kg Capacity – ISI marked Dry Chemical Powder (DCP) Type Fire Extinguishers: **03 Nos.**
3. 9 Liter Capacity – ISI marked Water Type Fire Extinguishers: **01 No.**
4. 4.5 kg Capacity – ISI marked Co2 Type Fire Extinguishers: **03 Nos.**
5. 3 kg Capacity – ISI marked Co2 Type Fire Extinguishers: **06 Nos.**
6. Sand Buckets (Set of 4 buckets – 4 x 4) **16 Nos.**
7. Route Marker / Exit / Safety related auto glow sign boards are installed **√Yes / No**
8. Electric wiring done with necessary LCB / MCB switches **√Yes / No**

This certificate is valid for one year from the date of issue

- Note: 1) Every year Fire Safety NOC should be renew from the certified officer
2) Fire NOC shall be taken from the, situated area of the school.



Sign:

Name:

Designation:

Alkaben I. Nayka

A. I. Nayka
તા. માંગરોળ કમ મંત્રી.
નાની નરોલી, ગ્રામ પંચાયત

તા. માંગરોળ, જિ. સુરત